



- GENERAL LIGHTING NOTES:**
- LIGHTING CALCULATIONS INCLUDE FUTURE LIGHT FIXTURES (\* PHASE 2 FIXTURES) IN ORDER TO MEET IESNA STANDARDS FOR THE FUTURE BUILD-OUT. FUTURE LIGHT FIXTURES WOULD NOT BE INSTALLED AS PART OF PHASE 1 AND ARE NOT LISTED IN THE LUMINAIRE SCHEDULE.
  - MOUNTING HEIGHT EQUATES BETWEEN THE LIGHT SOURCE AND THE GROUND PLANES FOR USING CALCULATION PHOTOMETRIC ANALYSIS, CUT POLES AS NEEDED
  - VOLTAGE TO BE VERIFIED BY ELECTRICAL ENGINEER PRIOR TO ORDERING
  - DRIVE CURRENT - REVIEW DRIVE CURRENT AND WATTAGE WITH ELECTRICAL ENGINEER AND CONTRACTOR BEFORE INSTALLATION
  - DIMMING TO BE VERIFIED BY ELECTRICAL ENGINEER PRIOR TO INSTALLATION. THE FIXTURE SHOULD BE SET AT THE PERCENTAGE (1/3 THE TOTAL POWER) AS SHOWN ON THE LIGHT SCHEDULE.
  - BASE MOUNT - SEE LIGHTING PLANS FOR THE FIXTURE'S ORIENTATION.
  - SEE LIGHTING PLANS AND DETAILS WITH SPECIFICATIONS FOR LIGHT FIXTURES, POLES, ARMS AND OTHER INFORMATION.

**LEGEND**

	PUBLIC ROAD FIXTURE
	PARKING LOT LIGHT
	PEDESTRIAN LIGHT
	BOLLARD
	CANOPY LIGHT
	PHASE 2 LIGHT FIXTURES
	1.00 CONTOUR LEVEL (ft)
	0.50 CONTOUR LEVEL (ft)
	0.20 CONTOUR LEVEL (ft)

PLAN  
REVISED  
06/17/2022

n/f  
Wind NRG Systems

n/f  
Wind NRG Systems

n/f  
Jolley Associat

revisions	date	revisions	date
Town Resubmittal	11-22-2019	Town Resubmittal	06-17-2022
Town Resubmittal	01-10-2020		
Town Resubmittal	03-14-2022		

