

1/12/24

Ryan & Renee Mobbs PO Box 564 Hinesburg, Vermont 05461

Re: PR & R Development LLC, WW-4-5629 Disposal Area certification, Observatory Road, Hinesburg, Vermont (Via Email)

Dear Renee & Ryan,

I am writing to follow up on our recent discussions regarding the installation of the disposal area specified in the above permit. During the month of January 2022, I met with Pat Miner, of Green Mountain Excavating, to stake out and review installation of the leachfield and wastewater connection from the accessory dwelling. Based on my inspections and a 1/26/22 inspection prior to covering of the leachfield, the disposal area has been constructed in reasonable conformance with the approved plans and is functioning as intended.

Since the septic tanks and proposed house location have been shifted from the original locations, it is recommended that the permit be amended to show the updated house location and appropriate water system information once the final location of the house is determined. Please let me know if plans are finalized for the future house and we can proceed with the amendment. If you have questions, please don't hesitate to call. Thank You.

Sincerely,

Spencer Harris, for

Vermont Contours, Inc.